



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

April 6, 2016
Subject: Salt Storage Shed
State WIN: 021248.00
Location: **Houlton**
Amendment No. 1

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following question has been received:

Question: Several sheathing details show 5/8 Advantech O.S.B tongue & groove, these are two different products please verify what is to be used .

Response: 5/8 T&G Advantech only is to be used. Stated in Special Provision; Section 06100; Rough Carpentry, Part 2- Products, 2.2 Plywood section C. All OSB shall be coated oriented strand board (OSB) sheathing in lieu of exterior wall sheathing, "Advantech" by Huber Industries.

Consider this change and information prior to submitting your bid on **April 20, 2016**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER